

FAQ – configuration profibus example for series SX502

Safety precautions

Important Information

Read these operating instructions before starting the unit. They provide you with important information on the use, safety and maintenance of the units. This helps you to protect yourself and prevent damage to the unit.



Information intended to help you to avoid death, bodily harm or considerable damage to property are highlighted by the warning Triangle shown here; it is imperative that this information be properly heeded.

Safety



components inside the units are energized with electricity during operation. For this reason, mounting and maintenance work may only be performed by professionally-trained personnel while observing the corresponding safety regulations.

The units do not have a power switch. They are operative as soon as the operating voltage is applied.

Intended use

The units are intended for use in industrial environments. They may only be operated within the limit values stipulated by the technical data.

When configuring, installing, maintaining and testing the units, the safety and accident-prevention regulations relevant to use in each individual case must be complied with.

Trouble-free, safe operation of the units requires proper transport, storage, installation, mounting and careful operation and maintenance of the units.

Mounting and Installation



The attachment options for the units were conceived in such a way as to ensure safe, reliable mounting.

The user must ensure that the attachment hardware, the unit carrier and the anchoring at the unit carrier are sufficient to securely support the unit under the given surrounding conditions.

The units are to be mounted in such a way that they can be opened up while mounted. Sufficient space for the cables must be available in the unit near the cable infeed.

Sufficient space is to be kept clear around the units to ensure air circulation and to prevent the build-up of heat resulting from use. The relevant information must be heeded in the case of units ventilated by other means.

FAQ – configuration profibus example for series SX502



When the housing fasteners are opened, the front frame of the housing hinges out upward or downward (depending on the unit version) automatically.

Grounding


All devices are equipped with a metal housing. They comply with safety class I and require a protective earth connection. The connecting cable for the operating voltage must contain a protective earth wire of a sufficient cross section (DIN VDE0106 part 1, DIN VDE 0411 part 1).

Other

Read first the chapter 1 of the manual.


1. connect your new SX502 over profibus dp on your plc and power supply

the best configuration to learn communicate SX502 over profibus dp is to connect only one display on plc and no other functions will be on plc than the example file.




FAQ – configuration profibus example for series SX502


2. Start Siemens Simatic Manager




3. extract the example file from the file folder



FAQ – configuration profibus example for series SX502




4. open the hardware configuration



FAQ – configuration profibus example for series SX502


5. change the profibus slave address on your favorite address



FAQ – configuration profibus example for series SX502

6. choose a configuration from hardware catalog and set it on the plug-in position of the profibus slave

(for example Online Text – 1 (byte) In – 8 (bytes) consistent out)





Attention!

Please remember the definition of consistent data bytes out (in this example is 8 Bytes)
 If you choose another configuration (for example 16 Bytes) you must set this value in FC3 at the hardware settings but in HEX.

FAQ – configuration profibus example for series SX502

7. change the E/A Address of the profibus slave configuration




Attention!

Please remember the definition of E/A addresses.

If you choose another definition (for example E-address 4 and A-address 10) you must set this value in FC3 at the hardware settings but in HEX.

FAQ – configuration profibus example for series SX502

8. save and translate hardware configuration and send it to the plc.



FAQ – configuration profibus example for series SX502

9. open FC3 („SX502 Communication“) and scroll down until displayed „set H E R E datas of hardware configuration“


change there the values that is set in the hardware configuration

Attention! Values must be enter in HEX. In hardware configuration the values are in DEC.

OutputAddr = 32 HEX (in hardware configuration 50 DEC)

InputAddr = 2 HEX (in hardware configuration 2 DEC)

LenConsData = 8 HEX (in hardware configuration 8 DEC)



```

// set H E R E datas of hardware configuration

L190: CALL "Set_Tx_Data"
    OutputAddr :=W#16#32           // see hardware configuration for details
    InputAddr  :=W#16#2            // output data in IO start here
    SrcDb      :=MW200             // input data in IO region start here
    SendDb     :=W#16#1            // number of DB to send
    LenConsData:=W#16#8            // number of DB to use as scratch buffer
    RETVAL     :=HW204             // number of bytes defined as consistant output
                                // temp storage for return value

// ** check return value of FC2 for errors (see function description of error codes)
L     MW 204                  // get return value of FC2
L     W#16#0                  // load compare value
==I
SPBN ERR9                     // return value 0x0000 ?
SPA  L199                     // branch to error handling for FC2
                                // done - no error

ERR1: L   MW 202              // error handling FC1 - check return value
L   W#16#8000                // FC1 returns "display busy" ?
==I
L   S5T#5S                  // compare equal
SE   T   1                    // load "long" 5 sec delay here for demonstration
                                // set extended pulse timer 1 if compare is TRUE, clear else
U   T   1                    // check for T1 to come up, i.e. busy timeout condition
SPBN ERR8                     // additional error handling for FC1

=   A   0.0                  // !!!! set A0.0 to signal lockup condition !!!!
L   B#16#0
T   DB1.DB8      0            // !!!! H E R E the communication is unlocked !!!!
SPA  ERR8                     // additional error handling for FC1


ERR8: BE
ERR9: BE
L199: BE
                                // include further error handling for FC1 here - skip for now
                                // include further error handling for FC2 here - skip for now
                                // done - no error

```

Drücken Sie F1, um Hilfe zu erhalten.  offline Abs < 5.2 Nw 1 Ze 100 Einfg

FAQ – configuration profibus example for series SX502

10. also in FC3 you set the marker bytes for choose the DB that will send if you control this marker byte



```

//<>----> M.0.0
//<>----> M#250MS
//<>----> M.2
//<>----> M.1.0
//<>----> M.0.0
//<>----> M#16#3
//<>----> MW.200
//<>----> L190


```

The screenshot shows an FC3 block in SIMATIC Manager. The code is annotated with yellow boxes and arrows:

- A red circle highlights the first marker byte `M.0.0`, with an arrow pointing to a yellow box labeled "Marker byte".
- An arrow points from the "Marker byte" box to the line `SST#250MS`.
- A yellow box labeled "DB no. to send" contains the values `2`, `1.0`, and `0.0`, which are the results of the marker byte selection.
- A red circle highlights the second marker byte `M#16#3`, with an arrow pointing to a yellow box containing comments for the next input and source DB.
- An arrow points from the "DB no. to send" box to the line `MW.200`.


FAQ – configuration profibus example for series SX502

11. save everything to the plc




FAQ – configuration profibus example for series SX502

12. open the variables sheet



	Operand	Symbol	Anzeigeformat	Statuswert	Steuerwert
1	M 0.0		BOOL	true	false
2	M 0.1		BOOL	false	false
3	M 0.2		BOOL	false	
4	M 0.3		BOOL	false	
5					

13. control the marker byte with keys „CTRL + 1“



	Operand	Symbol	Anzeigeformat	Statuswert	Steuerwert
1	M 0.0		BOOL	true	false
2	M 0.1		BOOL	false	false
3	M 0.2		BOOL	false	
4	M 0.3		BOOL	false	
5					

Now on the display of the SX502 will be text : „Welcome to Siebert Industrielektronik GmbH“
 This is the text in DB3.

If you control M0.1 the text that display called: „Innovation in display“
 This is the text in DB4.

If you control M0.2 you set a text with variables : SOLL: \$VS\$VS\$VS IST: \$VS\$VS\$VS
 This is the text in DB5.

And if you control M0.3 you only send variables on the text from DB5: 1 2 3 4 5 6
 This is the text in DB6.

FAQ – configuration profibus example for series SX502

14. If you want to send an individual text change only the text in DB3 and control the marker byte M0.0

In FC3 you can expand the function with the control of marker bytes if you have more text you would send. Then make a new DB with text and control it with a new marker byte.